

Grease Interceptor Service Monitoring Log



Scan for
Online Self
Reporting



Business Name:

Business License #:

Access Code:

Cleaning is required every 30 days or before the grease and solids combined reach 25% of the liquid capacity, whichever comes first. For all self-cleaned interceptors, before and after photos must be submitted within 7 days of cleaning to sourcecontrol@sylvanlake.ca.

Cleaning and monitoring records are required to be kept **onsite** for a minimum of two (2) years and be available upon request.

Date (yyyy/mm/dd)	Location of Grease Interceptor	Inspected	Cleaned	Bottom Solids Depth (inches)	Floating Grease Depth (inches)	Self-Cleaned			Third-Party
						Name of owner/ staff performing inspection/ cleaning	Before/ after photos taken and submitted?	Disposal location	Licensed service provider name
/ /		<input type="checkbox"/>	<input type="checkbox"/>	"	"		<input type="checkbox"/> Yes <input type="checkbox"/> No		
Comments:						Online self-reporting complete? <input type="checkbox"/>			
/ /		<input type="checkbox"/>	<input type="checkbox"/>	"	"		<input type="checkbox"/> Yes <input type="checkbox"/> No		
Comments:									
/ /		<input type="checkbox"/>	<input type="checkbox"/>	"	"		<input type="checkbox"/> Yes <input type="checkbox"/> No		
Comments:									
/ /		<input type="checkbox"/>	<input type="checkbox"/>	"	"		<input type="checkbox"/> Yes <input type="checkbox"/> No		
Comments:									
/ /		<input type="checkbox"/>	<input type="checkbox"/>	"	"		<input type="checkbox"/> Yes <input type="checkbox"/> No		
Comments:									
/ /		<input type="checkbox"/>	<input type="checkbox"/>	"	"		<input type="checkbox"/> Yes <input type="checkbox"/> No		
Comments:									

Thank you for your ongoing commitment to help keep Sylvan Lake a safe and environmentally responsible community! Sylvanlake.ca/sourcecontrol